

Certificate

It is confirmed to

ALDAĞ Isıtma Soğutma Klima San ve Tic A.Ş

Yakacık Cumhuriyet Mah Abdi İpekçi Cad. No 3
34876 Kartal / İstanbul, Turkey

that the in January 2010 tested Air Handling Unit in Hygienic Version

ALDAMED HYGIENIC AKS 900

of the range

AKS

fulfilled the requirements for hygienic air handling units according to

DIN 1946 Part 4: 2008.

The validity of the type examination for the whole series of hygienic air-handling units can only be confirmed, if all the conditions itemised in the test report have been met. Since DIN 1946 Part 4 is a standard which relates to a whole installation, the type examination cannot replace the tests laid down for a finished air-conditioning system in a building.

TÜV NORD Systems GmbH & Co. KG

Division Engineering

Test Laboratory for Ventilation, Air-Conditioning and Refrigeration

Langemarckstrasse 20, 45141 Essen, Germany

The Inspector



Dipl.-Ing. Monika Steimle

Essen, 30 April 2010